

Pile Dynamics 17-Jul-06 12:14		FS — 10	BN 115 SL 2597/ 3440/ 2	PJ: PN: HOPBAR	TG F2 -- US A2 F2 3.3
LE 39.6 ft AR 1.7 in2 EM 30000 Ksi SP 0.492 K/ft3 WS 16810 ft/s WC 16862 ft/s					
JC 0.40 FM 1.00 VM 1.00					
EA/C 30.3 Ks/ft UN KIPS 30.1 FR 20000 MB 30	DL -48 UT -1 PK 1 TM-PEAK				
F1 500 F2 213 A1 999 A2 1050	TS 12 TB 8.0	S T1 9.2	B 2L/C 4.7	PD: 11845-060 VA 1000	LP 0.00 ft LI 1.0

ACCEPT SQ-OFF FL-OFF PR-OFF
 VMX= 4.5 FMX= 69 AMX= 159
 EMX= 0.3 MEX= 135 FVP= 1.01



contact Pile Dynamics USA
 with your questions
 tel USA - 216 - 831- 6131
 fax USA - 216 - 831- 0916

ACCELEROMETER CALIBRATION N.I.S.T. Traceable
 SERIAL NUMBER: 11845
 CALIBRATION FACTOR: 1050 61V
 BAK (*5000): _____ DATE: 17-JUL-06
 PDA OPERATOR: *Alex*